

---

**From:** Mendoza, Roy [mailto:roy.mendoza@bchydro.com]  
**Sent:** Friday, May 30, 2008 10:33 AM  
**To:** tina zanetti  
**Cc:** Davidson, Joyce; Smeets, Joe  
**Subject:** RE: Electrical Upgrade at 1600 Beach Ave --Beach Towers

Hi Tina,

As far as the BC Hydro work is concerned, the electrical service to the building will be upgraded from the existing **overhead 600A 120/208V to 400A 347/600V underground**. This upgrade is necessary to continue the reliability of the electrical service to the building in view of the proposed installation of the additional electrical loads by Bell Mobility.

The existing overhead transformer bank at the back lane will be replaced and there will be some work in the back lane in the future for the installation of the underground ducts and cables. The existing overhead secondary wires and the overhead service drop to the building at the back lane will be taken down. Aesthetically, there will be an improvement at the back lane once this project is completed.

Your Property Manager will be advised and notified of the actual schedules of the BC Hydro work on the said lanes for the information of all tenants.

Please take note that the existing meters/service of the individual tenants will not be affected by this service upgrade as only the main service entrance to the building will be altered. By the way, your property manager or Bell Mobility electrical consultants or the owner of the building can best answer any inquiries relating to any work on private property.

Thank you for writing. I hope that I have answered your inquiries.

Regards,

Roy

---

**From:** tina zanetti [mailto:tinaz@shaw.ca ]  
**Sent:** 2008, May 30 9:35 AM  
**To:** Mendoza, Roy  
**Subject:** FW: Electrical Upgrade at 1600 Beach Ave --Beach Towers

Hello Mr. Mendoza ,

I sent an email to Ms. Davidson, which is attached below and she replied by sending me information that was already provided by you.

5/5/2009

My question to her was, to what is the extent of the electrical upgrade BC Hydro is doing on the Beach Towers at 1600 Beach Ave. in Vancouver ?

I await your immediate response.

Tina Zanetti

---

**From:** Davidson, Joyce [mailto:Joyce.Davidson@bchydro.com]  
**Sent:** Friday, May 30, 2008 8:49 AM  
**To:** tina zanetti  
**Cc:** Mendoza, Roy  
**Subject:** RE: Electrical Upgrade at 1600 Beach Ave --Beach Towers

I attach an email that was sent to you by Roy Mendoza our Design Technologist providing information on the electrical upgrade to Beach Towers .

This email provides all the information on the service upgrade that BC Hydro is responsible for.

Joyce Davidson

Joyce Davidson  
Customer Relations Manager  
Central Park Place - 14th floor  
Tel. 604-453-6525  
Fax: 604-453-9141  
email: joy ce.davidson@bchydro.com

---

**From:** tina zanetti [mailto:tinaz@shaw.ca ]  
**Sent:** 2008, May 30 8:14 AM  
**To:** Davidson, Joyce  
**Subject:** Electrical Upgrade at 1600 Beach Ave -- Beach Towers

Hello Ms. Davidson,

Would you advise me please advise as to what is the extent of the electrical upgrade BC Hydro is doing on the Beach Towers at 1600 Beach Ave. in Vancouver ?

I await your immediate response.

Tina Zanetti

---

Ask a question on any topic and get answers from real people. [Go to Yahoo! Answers.](#)